



CITY NEWS



DELAWARE CITY, DELAWARE

www.delawarecity.delaware.gov

JUNE 25, 2007

DELAWARE CITY WATER QUALITY REPORT

407 Clinton Street, Delaware City, DE 19706
PWSID – DE0000566 Report Written June 22, 2007

We are very pleased to provide you with this annual water quality report for 2006. We're also pleased to report that Delaware City drinking water meets or exceeds all the standards for reportable substances. You will see that substances such as iron, chloride, and sodium are commonly found in drinking water. They occur naturally and, at trace levels, are not harmful to drink. The report shows at what levels any substances were found during tests conducted from Jan. 1, 2006 - Dec. 31, 2006, unless otherwise specified. If you have any questions about this report and the quality of your water, please contact Paul Morrill, City Manager at (302) 834-4573. If you wish to learn more, please attend any of the regularly scheduled meetings of Mayor & Council held the third Monday of each month at 7:30 p.m. in the Town Hall, located at the address above.

The water serving your home comes from the Potomac aquifer via 2 wells at depths of 720 and 737 feet. This aquifer is confined and protected from the influence of past farming activities and saltwater intrusion. The Division of Public Health in conjunction with the Department of Natural Resources and Environmental Control has conducted source water assessments for nearly all community water systems in the state. For a copy of the assessment, contact Paul Morrill at the Delaware City Town Hall (302) 834-4573.

Please note that we recently renovated our treatment plant near the water tower. This renovation will help to improve the iron removal capacity at this plant. Both treatment plants have now been renovated within the past 6 years.

All sources of drinking water (whether a river, lake, spring, well, or pond) are subject to potential contamination by substances that are naturally occurring or man made. As water travels through the ground or over the surface of the land, it can dissolve naturally occurring substances, including radioactive substances. Additionally, some substances result from the presence of animals or human activity. These substances (both natural and man-made) can be microbes, inorganic or organic chemicals, pesticides/herbicides and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline mentioned above.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations established limits for contaminants in bottle water, which must provide the same protection for public health.

In the table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

90th PERCENTILE - A calculation based upon averaging the 4th and 5th highest lead/copper readings, used to determine compliance with the Lead and Copper Rule.

ACTION LEVEL - The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements which a water system must follow.

MAXIMUM CONTAMINANT LEVEL - the "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MAXIMUM CONTAMINANT LEVEL GOAL - the "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MAXIMUM DISINFECTION RESIDUAL LEVEL (MRDL) - the highest level of a disinfectant in drinking water. There is convincing evidence that addition of a disinfectant is necessary for the control of microbial contaminants.

MAXIMUM DISINFECTION RESIDUAL LEVEL GOAL (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NON-DETECTS (ND) - laboratory analysis indicates that the constituent is not present.

NOT REGULATED (N/R) - no MCL identified because this substance is unregulated.

PARTS PER BILLION (PPB) - one part per billion corresponds to one minute in 2,000 years or a single penny in \$10,000,000.

PARTS PER MILLION (PPM) - one part per million corresponds to one minute in two years or a single penny in \$10,000

City of Delaware City
407 Clinton Street
P. O. Box 4159
Delaware City, DE 19706



PRST STD
U.S. POSTAGE
PAID
MAILED FROM 19706
PERMIT NO. 13

BOXHOLDER
DELAWARE CITY, DE
19706

Delaware City Consumer Confidence Report (CCR) – June 2007

Parameter	Unit of Measure	Highest Level Allowed (MCL)	Ideal Goal (MCLG)	Highest Level Detected	Annual Range	Major Sources
Inorganic Contaminants						
Barium	ppb	2000	2000	22	21 - 22	Erosion of natural deposits
Chromium	ppb	100	100	1.2	1.1 – 1.2	Erosion of natural deposits
Fluoride	ppm	2	2	1.6	nd – 1.6	Naturally occurring in soil. Water additive that promotes strong teeth.
Nickel	ppb	100	100	0.8	nd – 0.8	
Disinfection/Disinfection By-product Contaminants						
Chlorine, Free Residual	ppm	4 (MRDL)	4 (MRDLG)	2.2	nd – 2.2	Disinfectant used in drinking water industry
Haloacetic Acids, total	ppb	60	0	4.9	1.7 – 8.2	By-product of drinking water chlorination
Dibromoacetic Acid	ppb	n/r		1.2	nd – 1.2	
Dichloroacetic Acid	ppb	n/r		5.7	1.7 – 5.7	
Monochloroacetic Acid	ppb	n/r		1	nd – 1	
Trichloroacetic Acid	ppb	n/r		1.5	nd – 1.5	
Trihalomethanes, total	ppb	80	0	21	15 - 30	By-product of drinking water chlorination
Bromodichloromethane	ppb	n/r		4.9	3 – 4.9	
Bromoform	ppb	n/r		1.5	nd – 1.5	
Chloroform	ppb	n/r		20.4	9 – 20.4	
Dibromochloromethane	ppb	n/r		3.6	2.7 – 3.6	
Unregulated Contaminants						
Alkalinity, Total	ppm	n/r		78	76 – 78	
Chloride	ppm	250	250	21	20 – 21	
Hardness, Total	ppm	n/r		6.2	n/a	
Iron	ppb	300	300	990	110 – 990	
pH, Field	0-14 scale	n/r		7.9	7.2 – 7.9	
Sodium	ppm	n/r		46	43 – 46	
Solids, Total Dissolved	ppm	500	500	136	120 - 136	
Lead & Copper						
		Action Level		90 th Percentile		
90th Percentile Lead (2004 Data)	ppb	15	0	7	nd - 54	Corrosion of household plumbing systems,
Number of Sites Exceeding Lead Action Level				1		Erosion of natural deposits
90th Percentile Copper (2004 Data)	ppb	1,300	0	460	15 - 670	Corrosion of household plumbing systems,
Number of Sites Exceeding Copper Action Level				0		Erosion of natural deposits
Microbiological Contaminants						
Total Coliform	Absent results in 100 % of samples collected					Naturally present in the environment.

Contaminants tested for, but not found.

Contaminants tested for, but not found.			
<p>Inorganic Contaminants</p> <p>Antimony Arsenic Beryllium Cadmium Mercury Nitrate Nitrite Nitrate/Nitrite Selenium Thallium</p>	<p>1,1,1,2-Tetrachloroethane 1,1,1-Trichloroethane 1,1,2,2-Tetrachloroethane 1,1,2-Trichloroethane 1,1-Dichloroethane 1,1-Dichloroethene 1,1-Dichloropropene 1,2,3-Trichlorobenzene 1,2,3-Trichloropropane 1,2,4-Trichlorobenzene 1,2,4-Trimethylbenzene 1,2-Dibromo-3-Chloropropane</p>	<p>Volatile Organic Contaminants</p> <p>2-Hexanone 3-chloro-1-propene 4-Chlorotoluene 4-Isopropyltoluene Acetone Acrylonitrile Bromobenzene Bromochloromethane Benzene Carbon Disulfide Carbon Tetrachloride Bromomethane Chlorobenzene Chloroethane Chloromethane cis-1,2-Dichloroethene cis-1,3-Dichloropropene Dibromomethane Dichlorodifluoromethane Ethyl methacrylate Ethylbenzene Hexachlorobutadiene Iodomethane Isopropylbenzene</p>	<p>m,p-Xylene Methyl Isobutyl Ketone (MIBK) Methyl methacrylate Methylene Chloride Methyl-t-butyl ether (MTBE) Naphthalene n-Butylbenzene n-Propylbenzene o-Xylene sec-Butylbenzene Styrene tert-Butylbenzene Tetrachloroethene Tetrahydrofuran (THF) Toluene tr-1,2-Dichloroethene tr-1,3-Dichloropropene trans-1,4-Dichlorobutene Trichloroethene Trichlorofluoromethane Vinyl acetate Vinyl chloride Xylenes, total</p>
<p>Radiological Contaminants</p> <p>Gross Alpha Emitters Gross Beta Emitters</p>	<p>1,2-Dibromoethane 1,2-Dichlorobenzene 1,2-Dichloroethane 1,2-Dichloropropane 1,3,5-Trimethylbenzene 1,3-Dichlorobenzene 1,3-Dichloropropane 1,4-Dichlorobenzene</p>		
<p>Disinfection By-Products</p> <p>Monobromoacetic Acid</p>	<p>2,2-Dichloropropane 2-Butanone (MEK) 2-Chloroethylvinyl Ether 2-Chlorotoluene</p>		
<p>1,2-Dibromo-3-Chloropropane 1,2-Dibromoethane 2,4,5-TP (Silvex) 2,4-D 2,4-dinitrotoluene 2,6-dinitrotoluene 2-Methyl Naphthalene 3-Hydroxycarbofuran 4,4'-DDE Acenaphthene Acenaphthylene Acetchlor Acifluorfen Alachlor Aldicarb Aldicarb Sulfone Aldicarb Sulfoxide Aldrin</p>	<p>Synthetic Organic Contaminants (Pesticides/Herbicides/Insecticides)</p> <p>Anthracene Atrazine Benzo(a)anthracene Benzo(a)pyrene Benzo(b)fluoranthene Benzo(g,h,i)perylene Benzo(k)fluoranthene Bis(2-ethylhexyl) phthalate Butachlor Butylbenzylphthalate Carbaryl Carbofuran Chrysene Dalapon Di(ethylhexyl)adipate Dibenzo(a,h)anthracene Dibenzofuran</p>	<p>Dicamba Dieldrin Diethylphthalate Dimethyl phthalate Di-n-butylphthalate Dinoseb Endrin Eptam (EPTC) Ethylene Dibromide Fluoranthene Fluorene Heptachlor Heptachlor Epoxide Hexachlorobenzene Hexachlorocyclopentadiene Indeno(1,2,3-cd)pyrene Lindane</p>	<p>Methiocarb Methomyl Methoxychlor Metolachlor Metribuzin Molinat Oxamyl (Vydate) PCBs Pentachlorophenol Phenanthrene Picloram Propachlor Propoxur Pyrene Simazine Terbacil Toxaphene</p>